



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Certificate No.: CE150303004670-A1

Product

Moulded Case Circuit-breakers

Applicant

Zhejiang Tengen Electrics Co.,Ltd.

TENGEN Industry Zone, Liushi, Yueqing, Zhejiang Province,
P.R.China

Type/model

TGB3-125B, TGB3-125C, TGB3-125D, TGB3H-125B, TGB3H-125C, TGB3H-125D

Technical data

Uimp:6kV;Ui:500V;Ue:AC230V(1P),AC400V(2P,3P,4P);
In:63A,80A,100A,125A; TGB3-125:Ics=Icu=6kA;TGB3H-125:Ics=7.5kA,Icu=10kA; Selectivity
Category:A;50/60Hz;1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No. CE-045-1C150615, the submitted sample of the above item complies with:

EN 60947-2:2006(4th Edition)+A1:2009+A2:2013

and fulfill testing requirement of the European Directive:

2006/95/EC

Date of issue: Apr.15,2016

Date of expiration: Aug.25,2018

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>