

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN42431

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME****SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC****CB TEST CERTIFICATE**Product
Produit

Miniature Circuit Breaker

Name and address of the applicant
Nom et adresse du demandeurZhejiang Tengen Electrics Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantZhejiang Tengen Electrics Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.ChinaName and address of the factory
Nome et adresse de l'usineZhejiang Tengen Electrics Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang
ProvinceNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

TENGEN

Model / Type Ref.
Ref. De typeTGB1N-80,TGBD-80,TGBG-80,TGBK-80,TGB1N-80N,TGB
D-80N,TGBG-80N,TGBK-80N,TGB1N-80H,TGBD-80H,TGB
G-80H,TGBK-80HAdditional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laAs shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce CertificatThis CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: Jan.24,2018

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0042456**

TGB1N-80,TGBD-80,TGBG-80,
TGBK-80,TGB1N-80N,TGBD-80N,
TGBG-80N,TGBK-80N,TGB1N-80H,
TGBD-80H,TGBG-80H,TGBK-80H
Ui:690V, Uimp:6kV;
Ue:AC220V/230V/240V/380V/400V/415V(1P),AC220V/230V/240V(1P+N),AC220V/230V/240V/3
80V/400V/415V(2P),AC380V/400V/415V(3P,3P+N,4P); In:63A,80A;
Type of instantaneous tripping
current: B,C,D;
TGB1N-80,TGBD-80,TGBG-80,TGBK-80:Ics=Icn:6kA;
Ics:7.5kA,Icn:10kA(2P only, AC220V/230V/240V);
TGB1N-80H,TGBD-80H,TGBG-80H,TGBK-80H: Ics:7.5kA, Icn:10kA;
Poles:1P,1P+N(1protected pole with a switched neutral pole),2P,3P,
3P+N(3 protected poles with a switched neutral pole), 4P.
TGB1N-80N, TGBD-80N,
TGBG-80N, TGBK-80N
Ics=Icn:6kA(AC220V/230V/240V); Poles: 2P

Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: Jan.24,2018

Signature:



Wang Kejiao