



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Certificate No.: CE180302005826

Product

Switch capacitor contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGCC1-63

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
(2018)FQIIDQCE-0152, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: May.30,2018

Valid until:

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE180302005826

TGCC1-63

Uimp:6kV;Ui:690V;lth:63A;Ue:AC220V/230V,AC380V/400V,AC660V/690V;

Ie:43A;

Utilization category:AC-6b;

Us:AC110V,AC220V,AC380V,AC400V,AC415V,50Hz;AC110V,AC220V,AC380V,AC400V,
AC415V,50/60Hz;

Qe:20kvar(220V/230V),35kvar(380V/400V),48kvar(660V/690V);3P;IP20;

Matching auxiliary contact:lth:10A, 1NO1NC;

Switch contactor: lth:10A,1NO,1NC;

AC-15:380V/0.95A,DC-13:220V/0.15A

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>