

Zhejiang Tengen Electrics Co., Ltd.
Ms. Zhang Xiaoxian
-
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Date : 21.02.2014
Our ref. : WCJ ZC10
Your ref.: Z.X.X.

Ref : R TÜV-Mark Approval

Type of Equipment : Moulded-case Circuit-breaker
Model Designation : See Certificate
Certificate No. : R 50272859 0001
Report No. : 14711540 001

Dear Ms. Zhang Xiaoxian,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.


Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


James Li

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50272859

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
Z.X.X.

Unser Zeichen *Our Reference*
ZC10-WCJ- 14711540 001

Ausstellungsdatum
21.02.2014

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Fertigungsstätte *Manufacturing Plant*

Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 60947-2:2006+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker (Moulded-case Circuit-breaker)

Type Designation	: 1) TGBZ-125B	8
	2) TGBZ-125C	1
	(TENGEN)	
Reference Temperature	: 30°C	
Utilization Category	: A	
Number of Poles/Protection poles	: 1/2/3/4 - pole	
Rated Operational Voltage(Ue)	: AC 230V(1-pole)	
	AC 400V(2/3/4-pole)	
Rated Current(In)	: 63/80/100/125A	
Rated Frequency	: 50/60Hz	
Rated Instantaneous Short-circuit Current(Ii)	: 1) 6In 2) 10In	
Rated Ultimate/Service Short-circuit Breaking Capacity(Icu/Ics)	: 10kA/7.5kA	
Rated Impulse Withstand Voltage	: 4.0kV	
Rated Insulation Voltage	: AC 500V	

Continued on page 0002

9

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle



James Li

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50272859

Blatt *Page*
0002

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum	<i>Date of Issue</i> (day/mo/yr)
Z.X.X.	ZC10-WCJ- 14711540 001	21.02.2014	

Genehmigungsinhaber *License Holder*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Fertigungsstätte *Manufacturing Plant*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-2:2006+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker (Moulded-case Circuit-breaker)

Continuation from page 0001

Suitability for Isolation : Yes

Suitability for using in IT System: Yes

Pollution degree : 3

The labelling requirements acc. to EU Directive 2001/95
have to be observed for distribution within the EEA.

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg
Tel.: (+49/221)8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221)8 06 - 39 35 http://www.tuv.com/safety

