

Zhejiang Tengen Electrics Co., Ltd.
Li Li
-
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P. R. China

Date : 05.06.2017
Our ref. : ZHB ZC10
Your ref.: L.L.

Ref : J Certificate of Surveyed Conformity

Type of Equipment : Fuse-holder
Model Designation : See Certificate
Certificate No. : J 50374666 0001
Report No. : 50075904 001

Dear Li Li,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



James Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity



Zertifikat Nr. *Certificate No.*
J 50374666

Blatt *Page*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
L.L.	ZC10-ZHB-50075904 001	05.06.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P. R. China

Fertigungsstätte *Manufacturing Plant*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60269-1:2007+A1+A2, excluding sub
clause 5.3.1
HD 60269-2:2013, excluding sub clause 7.1

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

(Fuse-holder)

Type Designation	: NHZ1-00 (TENGEN)	5
Rated Voltage and Current	: 1) AC 690V, DC 80V 160A 2) DC 80V 250A 3) DC 80V 600A	
Rated Power Acceptance	: >30W	
Peak Withstand Current	: 50kA (AC 690V) 25kA (DC 80V)	

The labelling requirements acc. to EU Directive 2001/95
have to be observed for distribution within the EEA.

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



James Li