

Zhejiang Tengen Electrics Co., Ltd.
Li Li
-
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P. R. China

Date : 01.06.2017
Our ref. : ZHB ZC10
Your ref.: L.L.

Ref : J Certificate of Surveyed Conformity

Type of Equipment : Fuse-links for The Protection of Semiconductor
Devices
Model Designation : See Certificate
Certificate No. : J 50374651 0001
Report No. : 50074673 001

Dear Li Li,

The above specified equipment has been tested and found to be in
accordance with the relevant requirements.


Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a
given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder
applies all information required in § 6 of the ProdSG related to name
and address of the manufacturer or his authorized representative /
importer, including their respective contact addresses on the product
prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



James Li

Enclosure

证书的详细信息请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity



Zertifikat Nr. Certificate No.
J 50374651

Blatt Page
0001

Ihr Zeichen Client Reference	Unser Zeichen Our Reference	Ausstellungsdatum Date of Issue
L.L.	ZC10-ZHB-50074673 001	01.06.2017 (day/mo/yr)

Genehmigungsinhaber License Holder
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P. R. China

Fertigungsstätte Manufacturing Plant
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P. R. China

Prüfzeichen Test Mark



Geprüft nach Tested acc. to
EN 60269-1:2007+A1+A2, excluding
sub clause 5.3.1
EN 60269-4:2009+A1+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

(Fuse-links for The Protection of Semiconductor Devices)

Type Designation	: NHZ1-00 NHZ1-00S (TENGEN)	6
Rated Voltage	: DC 80V	
Rated Current	: 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 300A, 315A, 350A, 400A, 500A, 600A	
Rated Breaking Capacity:	25kA	
Breaking Range	: g	
Utilization Category	: S	
Rated Power Dissipation:	≤30W at 100% of The Rated Current, ≤12W at 50% of The Rated Current	
Size	: 00	
Arc Voltage Limits	: ≤2000V (Peak Value)	
The labelling requirements acc. to EU Directive 2001/95 have to be observed for distribution within the EEA.		

6

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



James Li