



Ref. Certif. No.

CN46048

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.  
No.288 Central Avenue, Development Zone, Yueqing City,  
Zhejiang Province, P.R.China

*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGM3-800L, TGM3-800M, TGM3-800H

Additional information (if necessary may also be  
reported on page 2)

A sample of the product was tested and found  
to be in conformity with

IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which  
forms part of this Certificate

(2017)FQIIDQ-0524, (2018)FQIIDQ-0605

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Feb.19,2019

Signature:

Lu Mei



**CB 0050719**



TGM3-800L, TGM3-800M, TGM3-800H;

Uimp:8kV;

Ui: 800V;

Ue:AC400V/690V;

In:400A,500A,600A,630A,700A,800A;

Type of over-current release: Thermo-magnetic, Electro-magnetic;

Type L:

AC400V:Ics:35kA,Icu:50kA;

AC690V:Ics:10kA,Icu:15kA;

Type M:

AC400V:Ics:65kA,Icu:65kA;

AC690V:Ics:20kA,Icu:20kA;

Type H:

AC400V:Ics:65kA,Icu:85kA;

AC690V:Ics:20kA,Icu:30kA;

Selectivity category: A;

3P,3P+N(Type A: 3 protected poles with an uninterrupted neutral pole; Type D:3 protected poles with a protected uninterrupted neutral pole);4P(Type B:3 protected poles with a switched neutral pole; Type C:4 protected poles);

3P, 4P: suitable for isolation; 3P+N:Not suitable for isolation;

Matching auxiliary contact:FC38-400,

1NO1NC,2NO2NC,4NO4NC

Ui:690V

Ith:6A,

AC-15:AC(380/400)V/1A,DC-13:DC(220/230)V/0.15A;

Electronic annex in Appendix N:

Undervoltage release:QT38-400,Us:AC(220/230)V,AC(380/400)V;


Motor-operator:CD2-800, Us:AC(220/230)V,AC(380/400)V

Page 1 of 1

Additional information (if necessary)

Date: Feb.19,2019

Signature:



Lu Mei