



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190302006223

Product

AC contactor

Applicant

Zhejiang Tengen Smart Electrics Co.,Ltd.

No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Type/Model

TeC5-22,TeC5-22N,TeC5-25,TeC5-25N,TeC5-32,TeC5-32N,
TeC5-38,TeC5-38N

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-18D0049-S-A;03601-A-18D0049-S-B, the submitted sample(s) of the above
item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Mar.18,2019

Valid until: Mar.18,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE190302006223

TeC5-22, TeC5-22N, TeC5-25, TeC5-25N
TeC5-32, TeC5-32N, TeC5-38, TeC5-38N
Ui:690V;Uimp:6kV;
Ith:32A(TeC5-22, TeC5-22N), 40A(TeC5-25, TeC5-25N),
50A(TeC5-32, TeC5-32N, TeC5-38, TeC5-38N);
TeC5-22: AC-1:Ue:AC220V/230V/380V/400V, Ie:32A
AC-3:Ue:AC220V/230V/380V/400V, Ie:22A; Ue:AC660V/690V, Ie:14A
AC-4:Ue:AC220V/230V/380V/400V, Ie:8.5A; Ue:AC660V/690V, Ie:4A
TeC5-22N:AC-1:Ue:AC220V/230V/380V/400V, Ie:32A
AC-4:Ue:AC220V/230V/380V/400V, Ie:8.5A; Ue:AC660V/690V, Ie:4A
TeC5-25: AC-1:Ue:AC220V/230V/380V/400V, Ie:40A
AC-3:Ue:AC220V/230V/380V/400V, Ie:25A; Ue:AC660V/690V, Ie:18A
AC-4:Ue:AC220V/230V/380V/400V, Ie:8.5A; Ue:AC660V/690V, Ie:4.4A
TeC5-25N:AC-1:Ue:AC220V/230V/380V/400V, Ie:40A
AC-4:Ue:AC220V/230V/380V/400V, Ie:8.5A; Ue:AC660V/690V, Ie:4.4A
TeC5-32:AC-1:Ue:AC220V/230V/380V/400V, Ie:50A
AC-3:Ue:AC220V/230V/380V/400V, Ie:32A; Ue:AC660V/690V, Ie:22
AC-4:Ue:AC220V/230V/380V/400V, Ie:12A; Ue:AC660V/690V, Ie:7.5A
TeC5-32N:AC-1:Ue:AC220V/230V/380V/400V, Ie:50A
AC-4:Ue:AC220V/230V/380V/400V, Ie:12A; Ue:AC660V/690V, Ie:7.5A
TeC5-38:AC-1:Ue:AC220V/230V/380V/400V, Ie:50A
AC-3:Ue:AC220V/230V/380V/400V, Ie:38A; Ue:AC660V/690V, Ie:22A
AC-4:Ue:AC220V/230V/380V/400V, Ie:14A; Ue:AC660V/690V, Ie:8.9A
TeC5-38N:AC-1:Ue:AC220V/230V/380V/400V, Ie:50A
AC-4:Ue:AC220V/230V/380V/400V, Ie:14A; Ue:AC660V/690V, Ie:8.9A
Us: AC24V, AC36V, AC48V, AC110V, AC220V, AC380V, AC400V, AC415V, 50Hz;
AC24V, AC36V, AC48V, AC110V, AC220V, AC380V, AC400V, AC415V, 50/60Hz;
3P;
IP20;
Attached auxiliary contacts: (1NO1NC, 2 pairs):
Ith:10A;Ui:690V;Uimp:6kV;
AC-15:Ue/Ie:AC380V/0.95A, AC220V/1.6A

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Appendix

CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Page 2 of 2

Certificate No.: CE190302006223

DC-13:Ue/Ie:DC220V/0.15A.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>