



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE160304005132-A1

Product

AC contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGC1-40,TGC1-40N,TGC1-50,TGC1-50N,TGC1-65,TGC1-
65N,TGCG-40,TGCG-40N,TGCG-50,TGCG-
50N,TGCG-65,TGCG-65N,TGCJH-40,TGCJH-40N,TGCJH-
50,TGCJH-50N,TGCJH-65,TGCJH-65N

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
CE-045-1C172144, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jun.28,2019

Valid until: Jun.28,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0009145



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006326

Product

Signal light

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGAD1-□□;

Technical data

Uimp:2.5kV;Ui:660V;Ue:AC380V,AC220V,AC127V,AC110
V;AC/DC220V,AC/DC127V,AC/DC110V, AC/DC48V;FD
220V,FD 380V;φ22;IP40(with buzzer)/IP65

This is to certify that, on the basis of the tests undertaken as per Report No.
(2019)FQIIDQCE-0171, the submitted sample(s) of the above item complies with:

EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jun.28,2019

Valid until: Jun.28,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE160304005132-A1

TGC1-40,TGC1-40N,TGC1-50,TGC1-50N,TGC1-65,TGC1-65N,TGCG-40,TGCG-40N,TGCG-50,TGCG-50N,TGCG-65,TGCG-65N,TGCJH-40,TGCJH-40N,TGCJH-50,TGCJH-50N,TGCJH-65,TGCJH-65N;

Ui:690V;Uimp:6kV;

Us:50Hz,AC24V,AC36V,AC48V,AC110V,AC220V,

AC380V,AC400V,AC415V;50/60Hz,AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V;

3P;

TGC1-40,TGC1-40N,TGCG-40,TGCG-40N,TGCJH-40,TGCJH-40N

Ith:50A;AC-3:Ue:AC220V/230V,AC380V/400V;Ie:40A;Ue:AC660V/690V;Ie:34A;AC-

4:Ue:AC220V/230V,AC380V/400V;Ie:18,5A;Ue:AC660V/690V;Ie:9A;

TGC1-50,TGC1-50N,TGCG-50,TGCG-50N,TGCJH-50,TGCJH-50N

Ith:60A;AC-3:Ue:AC220V/230V,AC380V/400V;Ie:50A;Ue:AC660V/690V;Ie:39A;AC-

4:Ue:AC220V/230V,AC380V/400V;Ie:24A;Ue:AC660V/690V;Ie:12A;

TGC1-65,TGC1-65N,TGCG-65,TGCG-65N,TGCJH-65,TGCJH-65N

Ith:80A;AC-3:Ue:AC220V/230V,AC380V/400V;Ie:65A;Ue:AC660V/690V;Ie:42A;AC-4:Ue:AC220V/230V,AC380V/400V;Ie:28A;Ue:AC660V/690V;Ie:14A;

auxiliary switch AC-15 Ue/Ie:380V/0,95A,220V/1,6A;DC-13

Ue/Ie:220V/0,15A;Ui:690V;Ith:10A;Uimp:6kV;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>