



Test Report issued under the responsibility of:



TEST REPORT
IEC 60947-2
Low-voltage switchgear and controlgear - Part 2: Circuit-breakers

Report Reference No..... 00901-CB2017CQC-075291

Date of issue..... 2019-06-25

Total number of pages 303

CB Testing Laboratory Shanghai Testing & Inspection Institute for Electrical Equipment Co.,Ltd.
(STIEE)

Address 505 Wu Ning Rd. Shanghai 200063, P.R. CHINA

Applicant's name Zhejiang Tengen Electrics Co., Ltd.

Address Sulv Industry Zone, Liushi, Yueqing, Zhejiang, P.R. China

Test specification:

Standard IEC 60947-2:2006 (Fourth Edition) + A1: 2009 + A2: 2013

Test procedure CB scheme

Non-standard test
method..... N/A

Test Report Form No IEC60947_2G

Test Report Form(s) DEKRA Certification BV

Originator.....

Master TRF..... Dated 2013-11

Copyright © 2013 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description Moulded Case Circuit Breaker

Trade Mark TENGEN

Manufacturer Zhejiang Tengen Electrics Co., Ltd.

Model/Type reference TGM1N-320L/M/H/R, TGM1N-250L/M/H/R

Ue: AC230/240V(2P), AC380/400/415V(3P,3P+N,4P),

Ratings AC660/690V(3P,3P+N,4P)

In: TGM1N-250L/M/H/R:
100A,125A,140A,150A,160A,170A,180A,200A,225A,250A;

TGM1N-320L/M/H/R:100A,125A,140A,150A,160A,170A,180A,
200A,225A,250A,270A,280A,300A,315A,320A;

Testing procedure and testing location:		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Shanghai Testing & Inspection Institute for Electrical Equipment Co.,Ltd. (STIEE)
Testing location/ address.....:		505 Wu Ning Rd. Shanghai 200063, P.R. CHINA
Tested by (name + function + signature)		Cui Tao/Engineer
Approved by (name + function + signature)		Wei Qingyuan/Senior Engineer
<input type="checkbox"/>	Testing procedure: TMP	N/A
Testing location/ address.....:		N/A
Tested by (name + signature).....:		N/A
Approved by (name + signature).....:		N/A
<input type="checkbox"/>	Testing procedure: WMT	N/A
Testing location/ address.....:		N/A
Tested by (name + signature).....:		N/A
Witnessed by (name + signature)		N/A
Approved by (name + signature).....:		N/A
<input type="checkbox"/>	Testing procedure: SMT	N/A
Testing location/ address.....:		N/A
Tested by (name + signature).....:		N/A
Approved by (name + signature).....:		N/A
Supervised by (name + signature) ...:		N/A

Summary of testing:

In case of alternative test programs for circuit breakers with a different number of poles, the following program is used:

- ☐ Programme 1 (three pole fully tested)
- ☒ Programme 2 (four pole fully tested)
- ☐ Alternative program not applicable

Tests performed (name of test and test clause 1/3):

Type	Ue	In	Poles	Sequence
TGM1N-320L	AC415V	320A	2	I
TGM1N-320M	AC415V	320A	2	I
TGM1N-320L	AC690V	320A	4	I
TGM1N-320M	AC690V	320A	4	I
TGM1N-320H	AC690V	320A	4	I
TGM1N-320L	AC415V	320A	4	II
TGM1N-320L	AC415V	100A	4	II
TGM1N-320L	AC690V	320A	4	II
TGM1N-320M	AC415V	320A	4	II
TGM1N-320M	AC415V	100A	4	II
TGM1N-320M	AC690V	320A	4	II
TGM1N-320H	AC415V	320A	4	II
TGM1N-320H	AC415V	100A	4	II
TGM1N-320H	AC690V	320A	4	II
TGM1N-320R(Plug-in)	AC415V	320A	4	II
TGM1N-250R	AC415V	100A	4	II
TGM1N-320L	AC240V	320A	2	III
TGM1N-320L	AC240V	100A	2	III

Tests performed (name of test and test clause 2/3):

Type	Ue	In	Poles	Sequence
TGM1N-320L	AC415V	320A	2	III
TGM1N-320M	AC240V	320A	2	III
TGM1N-320M	AC240V	100A	2	III
TGM1N-320M	AC415V	320A	2	III
TGM1N-320M	AC415V	320A	2	III
TGM1N-320L	AC415V	320A	4	III
TGM1N-320L	AC415V	100A	4	III
TGM1N-320L	AC690V	320A	4	III
TGM1N-250L	AC415V	250A	4	III
TGM1N-320M	AC415V	320A	4	III
TGM1N-320M	AC415V	100A	4	III
TGM1N-320M	AC690V	320A	4	III
TGM1N-250M	AC415V	250A	4	III
TGM1N-320H	AC415V	320A	4	III
TGM1N-320H	AC415V	100A	4	III
TGM1N-320H	AC690V	320A	4	III
TGM1N-250H	AC415V	250A	4	III
TGM1N-320L	AC415V	320A	4	III(N)
TGM1N-320L	AC415V	100A	4	III(N)
TGM1N-320L	AC690V	320A	4	III(N)
TGM1N-320M	AC415V	320A	4	III(N)
TGM1N-320M	AC415V	100A	4	III(N)
TGM1N-320M	AC690V	320A	4	III(N)
TGM1N-320H	AC415V	320A	4	III(N)
TGM1N-320H	AC415V	100A	4	III(N)