



中国认可
国际互认
检测
TESTING
CNAS L1020

国家强制性产品认证 试验报告

■新申请 □变更 □监督 □复审 □其他:

申请编号: A2019CCC0302-3267677



(任务编号)

产品名称: 10kV 一体化柱上变台用熔断器式隔离开关

型 号: HR17N-630/30, HR17N-630/31,
HR17N-630/30M, HR17N-630/31M,
HR17N-630/30H, HR17N-630/31H,
HR17N-630/30MH, HR17N-630/31MH

检测机构: 苏州电器科学研究院股份有限公司



样品名称: 10kV 一体化柱上变台用 熔断器式隔离开关 型 号: HR17N-630/30, HR17N-630/31, HR17N-630/30M, HR17N-630/31M, HR17N-630/30H, HR17N-630/31H, HR17N-630/30MH, HR17N-630/31MH 商 标: / 样品数量: 8 台 样品来源: 工厂送样 收样日期: 2019-09-10 完成日期: 2019-10-22	委托人: 浙江天正电气股份有限公司 委托人地址: 浙江省乐清市柳市镇苏吕工 业区 生产者: 浙江天正电气股份有限公司 生产者地址: 浙江省乐清市柳市镇苏吕工 业区 生产企业: 浙江天正电气股份有限公司 生产企业地址: 浙江省乐清市经济开发 区中心大道 288 号
试验结论: 依据 GB/T14048.3-2017 检验合格	
本申请认证单元所覆盖的产品型号规格及相关情况说明:	
HR17N-630/30, HR17N-630/31, HR17N-630/30M, HR17N-630/31M, HR17N-630/30H, HR17N-630/31H, HR17N-630/30MH, HR17N-630/31MH Ui: 1000V; Uimp: 12kV; Ith: 315A, 630A; Ue: AC415V; Ie: 315A, 630A; Iq: 50kA; 使用类别: AC-23B; 50Hz; 极数: 3P; 配用的辅助触头: 一常开一常闭(2002010305025051) 型号: JW2-11; Ith: 3A AC-15: AC220V, 0.5A; DC-13: DC220V, 0.1A.	
主检: 朱文华 签字:  日期: 2019-11-07	
审核: 陆维导 签字:  日期: 2019-11-07	
签发: 陈 源 签字:  日期: 2019-11-07	
备注: HR17N-630/31H 630A: #01 HR17N-630/30H 630A: #02-#05 HR17N-630/30H 315A: #06 HR17N-630/30MH 630A: #07 配用熔断器: RT16J-3 (CCC 证书: 2019010308197286)	