



Ref. Certif. No.

CN49267

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Contactor Relays

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang  
Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Smart Electrics Co.,Ltd.  
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,  
Zhejiang Province, P.R.China

Ratings and principal characteristics

Uimp:6kV; Ui:660V; Ith:10A;  
Ue/Ie:AC-15:AC380V/0.95A;DC-13:DC220V/0.15A;  
Us:AC24V,36V,48V,110V,220V,380V 50Hz;  
AC24V,36V,48V,110V,220V,230V,380V,400V 50/60Hz;  
DC24V,48V,110V,220V; IP20

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be  
reported on page 2)

JZC4-40, JZC4-31, JZC4-22, JZC4-13, JZC4-04

A sample of the product was tested and found  
to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2019CQC-089762

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Dec.30,2019

Signature:

Lu Mei