



Ref. Certif. No.

CN49249

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Thermal Overload Relays

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

JRS2-135, JRS2-150, JRS2-180

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2019CQC-089258

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Dec.30,2019

Signature:

Lu Mei



Ref. Certif. No.

CN49249

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

JRS2-135,JRS2-150,JRS2-180

CB TEST CERTIFICATE

Uimp:8kV;

Ui:690V;

Product: Uic:AC690V;

JRS2-135:

Name and address of the manufacturer: Ie:55-80A,63-90A,80-110A,90-120A,110-135A;

JRS2-150:

Ie:55-80A,63-90A,80-110A,90-120A,110-135A,120-150A;

JRS2-180:

Name and address of the manufacturer:

Ie:55-80A,63-90A,80-110A,90-120A,110-135A,120-150A,135-160A,150-180A;

Tripping class:10A;

3P

Name and address of the factory:

Auxiliary contact:(body contact):

Note: When more than one factory, please report on page 2

INOINC

Ith:5A;

Rated AC 15:AC380V/0.95A, 220V/1.64A

Rated AC 15:AC380V/0.95A, 220V/1.64A

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Page 1 of 1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Dec.30,2019

Date:

Signature:

陆梅

Lu Mei

