



Ref. Certif. No.

CN49254

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Thermal Overload Relays

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

Uimp:6kV; Ui:690V; Ue:AC690V;
Ie:0.1-0.16A,0.16-0.25A,0.25-0.4A,0.4-0.63A,0.63-1A,1-1.6A,
1.6-2.5A,2.5-4A,4-6A,5.5-8A,7-10A,9-13A,12-18A,17-25A;
Tripping class:10A; 3P; IP20; Auxiliary contact:(body
contact):1NO1NC; Ith:5A; AC-15:AC380V/1.58A,
220V/2.73A

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

TENGEN

Model / Type Ref.

Additional information (if necessary may also be
reported on page 2)

JR28-25

A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2019CQC-089261

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Dec.30,2019

Signature:

Lu Mei