



中国国家强制性产品认证证书

证书编号: 2016010307897115

委托人名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产者(制造商)名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称、地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇柳乐路 332 号

产品名称和系列、规格、型号

塑料外壳式断路器

TGB1N-125、TGB1N-125H、TGBK-125、TGBK-125H、TGBD-125、TGBD-125H、
TGBG-125、TGBG-125H、TGBG-125A、TGBG-125HA、TGBH-125、TGBH-125H;
详细参数及型号解释见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2018 年 03 月 26 日 有效期至: 2021 年 08 月 30 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016 年 08 月 30 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主 任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010307897115

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded Case Circuit Breaker
TGB1N-125 、 TGB1N-125H 、 TGBK-125 、 TGBK-125H 、 TGBD-125 、 TGBD-125H 、 TGBG-125 、 TGBG-125H 、 TGBG-125A 、 TGBG-125HA 、 TGBH-125 、 TGBH-125H; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.26,2018

Valid until: Aug.30,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.30,2016

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 3 页

证书编号: 2016010307897115

纸 号: 1902401

TGB1N-125、TGB1N-125H、TGBD-125、TGBD-125H、TGBH-125、TGBH-125H

Ue: AC220V/230V/240V(1P/2P)、AC380V/400V/415V(2P、3P、4P);

Ui: 690V; Uimp: 4kV;

In: 63A、80A、100A、125A;

使用类别(Cat):

A 类; 过电流脱扣器类型: 热磁式;

分断能力: TGB1N-125、TGBD-125、

TGBH-125: Icu=Ics: 6kA; AC220V/230V/240V(2P): Icu: 10kA、Ics: 7.5kA;

TGB1N-125H、TGBD-125H、TGBH-125H: Icu: 10kA, Ics: 7.5kA;

适用频率: 50/60Hz;

极数: 1P、2P、3P、4P (均为保护极, 适用于隔离用)

TGBK-125、TGBK-125H、TGBG-125、TGBG-125H、TGBG-125A、TGBG-125HA

Ue: AC220V/230V/240V (1P/2P)、AC380V/400V/415V (2P/3P/4P);

DC60V/110V/125V(1P 外形)、125V/220V/250V(2P 外形)、

330V/375V(3P 外形)、440V/500V(4P 外形);

Ui: 690V; Uimp: 4kV;

In: 63A、80A、100A、125A;

使用类别(Cat): A 类; 过电流脱扣器类型: 热磁式;

分断能力: TGBK-125、TGBG-125、TGBG-125A: AC Icu=Ics: 6kA;

AC220V/230V/240V(2P): Icu: 10kA、Ics: 7.5kA; DC60V (1P 外形), 125V (2P

外形): Icu: 20kA、Ics: 15kA; DC110V/125V(1P 外形)、220V/250V(2P 外

形)、330V/375V(3P 外形)、440V/500V(4P 外形): Icu=Ics: 10kA; TGBK-125H、

TGBG-125H、TGBG-125HA: AC Icu: 10kA, Ics: 7.5kA; DC60V (1P 外形), 125V

(2P 外形): Icu: 20kA, Ics: 15kA; DC110V/125V(1P 外形), 220V/250V(2P 外

形), 330V/375V(3P 外形), 440V/500V(4P 外形): Icu=Ics: 10kA; 交流适用频

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 3 页

证书编号: 2016010307897115

纸 号: 1902401

率: 50/60Hz; 极数: AC 1P、2P、3P、4P; DC 1P 外形、2P 外形、3P 外形、4P 外形; (均为保护极, 适用于隔离用)

型号解释:

$\frac{TG}{(1)} \quad \frac{B}{(2)} \quad \frac{1N}{(3)} \quad - \quad \frac{125}{(4)} \quad \frac{\square}{(5)}$

- (1) 企业特征代号
- (2) 小型类断路器
- (3) 表示设计序号
- (4) 壳架等级额定电流
- (5) 短路分断能力级别:普通型 (无代号), 高分断型 (代号H)。

$\frac{TG}{(1)} \quad \frac{B}{(2)} \quad \frac{K}{(3)} \quad - \quad \frac{125}{(4)} \quad \frac{\square}{(5)}$

- (1) 企业特征代号
- (2) 小型类断路器
- (3) 表示设计序号
- (4) 壳架等级额定电流
- (5) 短路分断能力级别:普通型 (无代号), 高分断型 (代号H)。

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心



中国国家强制性产品认证证书

附 录

证书编号: 2016010307897115

第 3 页 共 3 页

纸 号: 1902401

TG B D - 125 □
(1) (2) (3) (4) (5)

- (1) 企业特征代号
- (2) 小型类断路器
- (3) 表示设计序号
- (4) 壳架等级额定电流
- (5) 短路分断能力级别:普通型(无代号), 高分断型(代号H)。

TG B G - 125 □ □
(1) (2) (3) (4) (5) (6)

- (1) 企业特征代号
- (2) 小型类断路器
- (3) 表示设计序号
- (4) 壳架等级额定电流
- (5) 短路分断能力级别:普通型(无代号), 高分断型(代号H)
- (6) 无代号: 普通市场; A: 专用市场

TG B H - 125 □
(1) (2) (3) (4) (5)

- (1) 企业特征代号
- (2) 小型类断路器
- (3) 表示设计序号
- (4) 壳架等级额定电流
- (5) 短路分断能力级别:普通型(无代号), 高分断型(代号H)。

注: 此附录与证书同时使用时有效。



主 任:



中国质量认证中心