



Ref. Certif. No.

CN50411

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Automatic Transfer Switching Equipment

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,  
P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,  
P.R.China

Name and address of the factory

Zhejiang Tengen Electric Co.,Ltd.  
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang  
Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui:500V(main circuit);400V(control and auxiliary circuits);Uimp:4kV(main  
circuit);2.5kV(control and auxiliary circuits); Ue:AC400V;Ie:  
10A,16A,20A,25A,32A,40A,50A,63A;Utilization Category:AC-33iB;Icn: Type  
M:6kA, Type H: 10kA; Icm(peak value): Type M:9.2kA, Type H:17kA;Class  
of equipment: CB;Method of controlling:RTSE(only intelligent type with  
communication controller), ATSE;3P, 4P;IP20.

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGQ1N-63M/3,TGQ1N-63M/4,TGQ1N-63H/3,TGQ1N-63H/4;

Additional information (if necessary may also be  
reported on page 2)A sample of the product was tested and found  
to be in conformity withIEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in  
conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010As shown in the Test Report Ref. No. which  
forms part of this Certificate

03601-A-19CB0048-S

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Jun.11,2020

Signature:

Lu Mei

CB 0057579