



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200303006933

Product

Miniature circuit breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TeB7E-80;

Technical data

Uimp: 6kV;Ui: 690V;Ue: AC230V;In:
6A,10A,16A,20A,25A,32A,40A,50A,63A,80A;Instantaneous
tripping current: B,C,D Ics:6kA;Icn:6kA;poles:
1P,2P;Applicable for isolation

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2020CQC0303-011115, the submitted sample(s) of the above item complies
with:

EN 60898-1:2003 + A13:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Sep.02,2020

Valid until: Sep.02,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>