





Test Report issued under the responsibility of:



TEST REPORT IEC 60947-6-1 Low-voltage switchgear and controlgear Part 6-1: Multiple function equipment – Transfer switching equipment	
Report Number.....	03601-A-20CB0029-S
Date of issue	2020-07-24
Total number of pages	60
Name of Testing Laboratory preparing the Report.....	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)
Applicant's name	Zhejiang Tengen Electric Co., Ltd.
Address.....	Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Test specification:	
Standard	IEC 60947-6-1:2005, AMD1:2013 for use in conjunction with IEC 60947-1:2007, AMD1:2010
Test procedure	CB Scheme
Non-standard test method	N/A
Test Report Form No.	IEC60947_6_1C
Test Report Form(s) Originator....	SGS Fimko Ltd
Master TRF	Dated 2019-07-02
Copyright © 2019 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer:	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

Test item description	Automatic Transfer Switching Equipment	
Trade Mark	TENGEN	
Manufacturer.....	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China	
Model/Type reference	TGQ1NPL-63,TGQKPL-63	
Ratings	Ui:800V(main circuit);500V(control and auxiliary circuits); Uimp:8kV(main circuit);4kV(control and auxiliary circuits); Ith: 63A; Ue: AC230V(2P),AC400V(3P,4P); Ie: 16A,20A,25A,32A,40A,50A,63A; Utilization Category:AC-33A; Icm: 17kA; Icw: 10kA/30ms;Iq:120kA; Class of equipment: PC; Method of controlling:ATSE; 2P, 3P, 4P.	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/> CB Testing Laboratory:	Suzhou Electrical Apparatus Science Research Institute Co., Ltd.(EETI)	
Testing location/ address	No.7 Yonghe Street, Binhe Road, New District, Suzhou,China	
Tested by (name, function, signature)	Zhu Wenhua (Team leader)	
Approved by (name, function, signature) ..	Chen Yuan (Supervisor)	
<input type="checkbox"/> Testing procedure: CTF Stage 1:		
Testing location/ address		
Tested by (name, function, signature)		
Approved by (name, function, signature) ..		
<input type="checkbox"/> Testing procedure: CTF Stage 2:		
Testing location/ address		
Tested by (name, function, signature)		
Witnessed by (name, function, signature) .:		
Approved by (name, function, signature) ..		
<input type="checkbox"/> Testing procedure: CTF Stage 3 or 4:		
Testing location/ address		
Tested by (name, function, signature)		
Witnessed by (name, function, signature) .:		
Approved by (name, function, signature) ..		
Supervised by (name, function, signature) :		