



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006914

Product

Automatic Transfer Switching Equipment

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGQ1NPL-630,TGQKPL-630;

Technical data

Ui:800V(main circuit);500V(control and auxiliary circuits);Ith:
630A;Uimp:8kV(main circuit);4kV(control and auxiliary circuits);
Ue: AC230V(2P),AC400V(3P,4P);Ie:
250A,315A,350A,400A,500A,630A;Utilization
Category:AC-33B;Icm: 40kA;Icw: 20kA/60ms; Iq:120kA;Class
of equipment: PC;Method of controlling:ATSE;2P, 3P, 4P.

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-20D0046-S, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Aug.24,2020

Valid until: Aug.24,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010364