



Ref. Certif. No.

CN49522

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Automatic Transfer Switching Equipment

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGQ1N-400L/3,TGQ1N-400L/4,TGQ1N-400M/3,TGQ1N-400
M/4,TGQ1N-630L/3,TGQ1N-630L/4,TGQ1N-630M/3,TGQ1N
-630M/4;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in
conjunction with IEC 60947-1:2007 (5th Edition) + AMD
1:2010As shown in the Test Report Ref. No. which
forms part of this Certificate

03601-A-19CB0040-S

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Mar.02,2020

Signature:

Lu Mei

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

TGO1N-400L/3, TGO1N-400L/4, TGO1N-400M/3, TGO1N-400M/4

CB TEST CERTIFICATE

TGQ1N-630L/3, TGQ1N-630L/4, TGQ1N-630M/3, TGQ1N-630M/4;

Product

Ui:800V(main circuit);400V(control and auxiliary circuits);

Uimp:8kV(main circuit);2.5kV(control and auxiliary circuits);

Name and address of the applicant

Ue:AC400V;

Ie: 250A,315A,350A,400A(with TGM1N-400L,TGM1N-400M Circuit-breaker),

400A,450A,500A,630A(with TGM1N-630L,TGM1N-630M Circuit-breaker);

Name and address of the manufacturer

Utilization Category:AC-33B;

Icn: Type L:50kA, Type M: 70kA;

Name and address of the factory

Icm(peak value): Type L:105kA, Type M:154kA;

Note: For more details, please report on page 2

Class of equipment: CB;

Method of controlling:

Rating in principal circuit type

RTSE(only intelligent type with communication controller),ATSE;

3P, 4P.

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Page 1 of 1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Mar.02,2020

Date:

Signature:

陆梅

Lu Mei

