



| <b>TEST REPORT</b><br><b>EN 60947-2</b><br><b>Low-voltage switchgear and controlgear - Part 2: Circuit-breakers</b>   |  |
|---|--|
| Report Number..... :  | 00901-CE2020CC C0303-011349  |
| Date of issue..... :  | 2020-09-16   |
| Total number of pages .....   | 219  |
| Name of Testing Laboratory preparing the Report .....   | Shanghai Testing & Inspection Institute for Electrical Equipment Co.,Ltd (STIEE)   |
| Applicant's name .....  | Zhejiang Tengen Electric Co.,Ltd.  |
| Address..... :  | Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China  |
| <b>Test specification:</b>  |  |
| Standard .....  | EN 60947-2:2017  |
| Test procedure .....  | CCA Scheme   |
| Non-standard test method .....  | N/A  |
| Test Report Form No. .... :   | 60947_2H   |
| Test Report Form(s) Originator .... :   | DEKRA Certification B.V.   |
| Master TRF .....  | Dated 2017-04  |
| <p><b>Copyright © 2017 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b></p> <p>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</p> <p>If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.</p> <p><b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b></p> |  |
| <b>Non-delay disclaimer:</b>  |  |
| <p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>  |  |
| Test item description..... :  | Moulded case circuit breaker   |
| Trade Mark..... :   | Tache  |
| Manufacturer .....  | Zhejiang Tengen Electric Co., Ltd.   |
| Model/Type reference .....  | TeM5ED-400M, TeM5ED-400H, TeM5ED-630M, TeM5ED-630H   |
| Ratings .....   | Ue:AC380V/AC400V/AC415V<br>In:160~400A (adjustable )(TeM5ED-400M, TeM5ED-400H)<br>In:250~630A (adjustable ) (TeM5ED-630M, TeM5ED-630H) |