



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200303007031

Product

Moulded Case Circuit-breakers

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TeM5ED-400M, TeM5ED-400H, TeM5ED-630M,
TeM5ED-630H

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2020CQC0303-011349, the submitted sample(s) of the above item complies
with:

EN60947-2:2017

and fulfills testing requirements of the European Directive:

Low Voltage Directive(LVD): 2014/35/EU

Valid from: Nov.26,2020

Valid until: Nov.26,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE200303007031

TeM5ED-400M, TeM5ED-400H, TeM5ED-630M, TeM5ED-630H;

Uimp:8kV;

Ui:1000V;

Ue:AC380V/AC400V/AC415V;

In:

160-400A (adjustable) (TeM5ED-400M, TeM5ED-400H);

250-630A (adjustable) (TeM5ED-630M, TeM5ED-630H);

Over-current release: electronic;

Ics:50kA(M),65kA(H) ;

Icu:50kA(M),85kA(H) ;

Selectivity category: B;

3P,3P+N;

50Hz/60Hz;

Applicable for isolation(except for 3P+N);

IP20 (except for the terminals) ;

Auxiliary contact and alarm contact:

OF-M, SD-M;

1NO1NC,2NO2NC,4NO4NC;

Ith: 3A;

AC-15 :Ue/Ie:AC380V/AC400V/AC415V/0.3A;

DC-13 :Ue/Ie:DC110V/DC220V/DC250V/0.15A

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>