



产品认证证书

证书编号: CQC2019010302252483

申请人名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江天正电气股份有限公司 (V038950)
浙江省乐清市经济开发区中心大道 288 号

产品名称和系列、规格、型号

熔断器式隔离开关

HR17N-400/30H, HR17N-400/31H, HR17N-400/30MH, HR17N-400/31MH, HR17N-400/30M, HR17N-400/31M, HR17N-400/30, HR17N-400/31; U_i : 1000V; U_{imp} : 12kV; U_e : AC415V/690V; $I_{th}=I_e$: 125A, 160A, 200A, 224A, 250A, 315A, 350A, 400A; I_q : 100kA(415V), 50kA(690V); 使用类别: AC-23B(415V), AC-22B(690V); 极数: 3P; 配用的辅助触头(1NO1NC): (2002010305025051) I_{th} : 3A; U_i : 220V; U_{imp} : 2.5kV; AC-15: U_e/I_e : AC220V/0.5A, DC-13: U_e/I_e : DC220V/0.1A.

产品标准和技术要求

GB/T14048. 3-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 05 月 29 日 有效期至: 2024 年 11 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0284000



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010302252483

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd. (V038950)
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse Switch Disconnecter

HR17N-400/30H, HR17N-400/31H, HR17N-400/30MH, HR17N-400/31MH, HR17N-400/30M, HR17N-400/31M, HR17N-400/30, HR17N-400/31; Ui:1000V; Uimp:12kV; Ue: AC415V/690V; Ith=Ie:125A,160A,200A,224A,250A,315A,350A,400A; Iq:100kA(415V), 50kA(690V); Utilization Category:AC-23B(415V), AC-22B(690V); Poles:3P; Attached Auxiliary Contacts(1NO1NC): (2002010305025051)Ith:3A; Ui:220V; Uimp:2.5kV; AC-15:Ue/Ie: AC220V/0.5A,DC-13: Ue/Ie: DC220V/0.1A.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: May.29,2020

Valid until: Nov.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0284000



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2019010302252483

申请编号 Application No. : A2020CCC0302-3538237

申请人(委托人) Applicant: 浙江天正电气股份有限公司 / Zhejiang Tengen Electric Co.,Ltd.

证书编号 Certificate No.(变更前 Original): 2019010302252483

变更产品名称: 熔断器式隔离开关

Name of Product Modified: Fuse Switch Disconnecter

变更情况 Situation of Modification (见下表 See table below) :

序号	项目 Item	变更前 Original	变更后 Present
1	绝缘材料操作手柄型号规格/牌号变更	PC(黑色/灰色)	PA6(黑色/灰色)
2	绝缘材料操作手柄制造商(生产厂)变更	温州市君正电器有限公司 浙江金莱勒电气有限公司 乐清市精源电气有限公司	温州市君正电器有限公司 浙江金莱勒电气有限公司 浙江宏环电器有限公司

现批准以上变更。

Above Modification is approved. The present will replace the original.

批准日期(Date): 2020年10月22日

第 1 页 / 共 1 页



主任:

陆梅



中国质量认证中心