

产品认证证书

II型自愿认证

证书编号: CQC2002010308025029

发证日期: 2020年08月24日
有效期至: 2031年05月20日

委托人名称 及注册地址	浙江天正电气股份有限公司 浙江省乐清市柳市镇苏吕工业区
制造商名称 及注册地址	浙江天正电气股份有限公司 浙江省乐清市柳市镇苏吕工业区
生产企业名称 及生产地址	浙江天正电气股份有限公司 浙江省乐清市柳市镇柳乐路 332 号
产品名称和系列、 规格、型号	刀型触头熔断器 RT16Z-A3,RT16Z-A3G,RT16Z-3G,RT16Z-3,RT16-A3,RT16-A3G,RT16-3G,RT16-3; 参数详 见附件
产品标准和技术要求	GB/T 13539.2-2015
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056309

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2002010308025029

Valid from: Aug.24,2020

Valid until: May.20,2031

NAME AND REGISTERED
ADDRESS OF THE APPLICANT

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION
OF THE FACTORY

Zhejiang Tengen Electric Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL
AND SPECIFICATION

Fuses with fuse-links with blade contacts
RT16Z-A3,RT16Z-A3G,RT16Z-3G,RT16Z-3,RT16-A3,RT16-A3G,RT16-3G,RT16-3; See the
Appendix

THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS

GB/T 13539.2-2015

TYPE OF CERTIFICATION
SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0056309

产品认证证书

II型自愿认证

附 录

证书编号: CQC2002010308025029

第 1 页 共 1 页

纸 号: 56309

熔断体型号:

RT16Z-A3,RT16Z-A3G,RT16Z-3G,RT16Z-3,RT16-A3,RT16-A3G,RT16-3G,RT16-3;

熔断体的额定电压 U_n : AC500V/AC690V,DC440V;

熔断体的额定电流 I_n : 315A,400A,500A,630A(AC500/690V,DC440V),800A(AC690V);

额定短路能力 I_l : 315-630A:120kA/AC500V,50kA/AC690V,100kA/DC440V;

800A:100kA/AC690V;

分断范围和使用类别: gG;

熔断器支持件型号: RT16-3,RT16Z-3;

熔断器支持件的额定电压 U_n : AC690V(RT16-3,RT16Z-3),DC440V(RT16Z-3);

熔断器支持件的额定冲击耐受电压 U_{imp} : 6kV;

熔断器支持件的额定电流 I_n : 800A;

极数: 1P.

注: 此附录与证书同时使用时有效。



中国质量认证中心

