

产品认证证书

II型自愿认证

证书编号: CQC2015010307749809

发证日期: 2020年08月24日

有效期至: 2031年05月20日

委托人名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

制造商名称 浙江天正电气股份有限公司
及注册地址 浙江省乐清市柳市镇苏吕工业区

生产企业名称 浙江天正智能电器有限公司
及生产地址 浙江省嘉兴市秀洲区中山西路 2777 号

产品名称和系列、规格、型号 万能式断路器
THW3-2500M、THW3-2500M/4、THW3-2500H、THW3-2500H/4;具体参数请见附件

产品标准和技术要求 GB/T14048.2-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0056381

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010307749809

Valid from: Aug.24,2020

Valid until: May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Zhejiang Tengen Electrics Co.,Ltd. Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Zhejiang Tengen Electrics Co.,Ltd. Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China
NAME AND LOCATION OF THE FACTORY	Zhejiang Tengen Smart Electrics Co.,Ltd. No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	Air Circuit-breaker THW3-2500M、THW3-2500M/4、THW3-2500H、THW3-2500H/4;See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T14048.2-2008
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0056381

产品认证证书

II型自愿认证

附 录

第 1 页 共 1 页

证书编号: CQC2015010307749809

纸 号: 56381

THW3-2500M、THW3-2500M/4、 THW3-2500H、THW3-2500H/4;

Ue: AC400V/ AC690V; Ui: 1000V;

In: 630A、800A、1000A、1250A、1600A、2000A、2500A;

过电流脱扣器类型: 智能化;

M 型: 当Ue=AC400V 时, Icu: 65kA, Ics: 65kA, Icw: 65kA/1s;

当Ue=AC690V 时, Icu: 55kA, Ics: 55kA, Icw: 55kA/1s;

H 型: 当Ue=AC400V 时, Icu: 85kA, Ics: 85kA, Icw: 85kA/1s;

当Ue=AC690V 时, Icu: 65kA, Ics: 65kA, Icw: 65kA/1s;

使用类别: B;

极数 : 3P、4P;

配用的辅助触头 (4NO4NC、5NO5NC、6NO6NC) :

Ith: 6A;

AC-15: Ue/Ie: AC400V/0.9A, AC230V/1.5A;

DC-13: Ue/Ie: DC220V/0.27A, DC110V/0.55A

符合附录N 的电子附件:

欠压脱扣器: AC230, AC400V

分励脱扣器: AC230, AC400V; DC110V, DC 220V

注: 此附录与证书同时使用时有效。



中国质量认证中心

