

产品认证证书

II型自愿认证

证书编号: CQC2007010304223758

发证日期: 2020年08月24日

有效期至: 2031年05月12日

委托人名称	浙江天正智能电器有限公司
及注册地址	浙江省嘉兴市秀洲区中山西路 2777 号
制造商名称	浙江天正智能电器有限公司
及注册地址	浙江省嘉兴市秀洲区中山西路 2777 号
生产企业名称	浙江天正智能电器有限公司
及生产地址	浙江省嘉兴市秀洲区中山西路 2777 号
产品名称和系列、规格、型号	交流接触器 THC1-25, THC1-32 U: 690V; AC-3, AC-4; THC1-25: Ith: 40A; AC-3: Ue/Ie: AC220V/380V/25A, AC660V/18A; AC-4: Ue/Ie: AC220V/380V/8.5A, AC660V/4.4A; THC1-32: Ith: 50A; AC-3: Ue/Ie: AC220V/380V/32A, AC660V/21A; AC-4: Ue/Ie: AC220V/380V/12A, AC660V/7.5A; 3P; U _s : AC24V, 36V, 48V, 110V, 127V, 220V, 380V; 配用的辅助触头: 1NO, 1NC; Ith=10A; AC-15: Ue/Ie: AC120V/6A; AC220V/230V/240V/3A; AC380V/400V/415V/1.9A; AC480V/1.5A; AC500V/1.4A; AC600V/660V/1.2A; DC-13: Ue/Ie: 125V/0.55A; 220V/250V/0.27A
产品标准和技术要求	GB/T14048.4-2010
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人:

陈昕

主任:

陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0040409

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2007010304223758

Valid from: Aug.24,2020

Valid until: May.12,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China

**NAME AND LOCATION
OF THE FACTORY**

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL
AND SPECIFICATION**

AC Contactor
THC1-25,THC1-32
Ui:690V;AC-3,AC-4;THC1-25:Ith:40A;AC-3:Ue/Ie:AC220V/380V/25A,AC660V/18A;AC-4:Ue/Ie:AC220V/380V/8.5A,AC660V/4.4A;THC1-32:Ith:50A;AC-3:Ue/Ie:AC220V/380V/32A,AC660V/21A;AC-4:Ue/Ie:AC220V/380V/12A,AC660V/7.5A;3P; Us:AC24V,36V,48V,110V,127V,220V,380V;Auxiliary Contact:1NO,1NC:Ith=10A;AC-15:Ue/Ie:AC120V/6A;AC220V/230V/240V/3A; AC380V/400V/415V/1.9A;AC480V/1.5A;AC500V/1.4A;AC600V/660V/1.2A; DC-13:Ue/Ie:125V/0.55A;220V/250V/0.27A
GB/T14048.4-2010

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

陈昕

PRESIDENT:

陆楠

CHINA QUALITY CERTIFICATION CENTRE

