

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGCA-0911,TGCA-0911N,TGCA-1211,TGCA-1211N,TGCA-
1611,TGCA-1611N;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which
forms part of this Certificate

(2021)FQIIDQ-0834

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.13,2022

Signature:

谢肇煦

Xie ZhaoXu

CB 0066411

TGCA-0911, TGCA-0911N, TGCA-1211, TGCA-1211N, TGCA-1611, TGCA-1611N;

Uimp:6kV;Ui:690V;Ue:AC220/230V,AC380/400V,AC660/690V;

TGCA-0911: Ith:20A;

AC-1:20A(AC220/230V,AC380/400V);

AC-3:9A/9A/6.6A(AC220/230V,AC380/400V,AC660/690V);

AC-4:3.5A/3.5A/1.5A(AC220/230V,AC380/400V,AC660/690V);

TGCA-1211: Ith:25A;

AC-1:25A(AC220/230V,AC380/400V);

AC-3:12A/12A/8.9A(AC220/230V,AC380/400V,AC660/690V);

AC-4:5A/5A/2A(AC220/230V,AC380/400V,AC660/690V);

TGCA-1611: Ith:25A;

AC-1:25A(AC220/230V,AC380/400V);

AC-3:16A/16A/8.9A(AC220/230V,AC380/400V,AC660/690V);

AC-4:7.7A/7.7A/3.5A(AC220/230V,AC380/400V,AC660/690V);

TGCA-0911N: Ith:20A;

AC-1:20A(AC220/230V,AC380/400V);

AC-4:3.5A/3.5A/1.5A(AC220/230V,AC380/400V,AC660/690V);

TGCA-1211N: Ith:25A;

AC-1:25A(AC220/230V,AC380/400V);

AC-4:5A/5A/2A(AC220/230V,AC380/400V,AC660/690V);

TGCA-1611N: Ith:25A;

AC-1:25A(AC220/230V,AC380/400V);

AC-4:7.7A/7.7A/3.5A(AC220/230V,AC380/400V,AC660/690V);

Utilization category:

AC-1(TGCA-0911, TGCA-0911N, TGCA-1211, TGCA-1211N,
TGCA-1611, TGCA-1611N),

AC-3(TGCA-0911, TGCA-1211, TGCA-1611),

AC-4(TGCA-0911, TGCA-0911N, TGCA-1211, TGCA-1211N,
TGCA-1611, TGCA-1611N);

Us:AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,
AC415V,50Hz;

Page 1 of 2

Additional information (if necessary)

Date: Jan.13,2022

Signature:

谢肇煦

Xie ZhaoXu

IEC

IECEE

Ref. Certif. No.

CN55876

AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;3P;
Auxiliary contact:1NO1NC;Uimp:6kV,Ui:690V,Ith:10A;
AC-15:Ue/Ie:AC380V/0.95A,AC220V/1.6A;
DC-13:AC220V/0.15A.

Page 2 of 2

Additional information (if necessary)

Date: Jan.13,2022

Signature:

谢肇煦
Xie ZhaoXu