



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220302007538

Product

AC contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Solv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGCA-0911,TGCA-0911N,TGCA-1211,TGCA-1211N,TGC
A-1611,TGCA-1611N;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
(2021)FQIIDQCE-0250, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jan.11,2022

Valid until: Jan.11,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

CE 0012720



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE220302007538

TGCA-0911, TGCA-0911N, TGCA-1211, TGCA-1211N,
TGCA-1611, TGCA-1611N
Uimp:6kV; Ui:690V; Ue:AC220/230V, AC380/400V, AC660/690V;
TGCA-0911: Ith:20A;
AC-1:20A(AC220/230V, AC380/400V);
AC-3:9A/9A/6.6A(AC220/230V, AC380/400V, AC660/690V);
AC-4:3.5A/3.5A/1.5A(AC220/230V, AC380/400V, AC660/690V);
TGCA-1211: Ith:25A;
AC-1:25A(AC220/230V, AC380/400V);
AC-3:12A/12A/8.9A(AC220/230V, AC380/400V, AC660/690V);
AC-4:5A/5A/2A(AC220/230V, AC380/400V, AC660/690V);
TGCA-1611: Ith:25A;
AC-1:25A(AC220/230V, AC380/400V);
AC-3:16A/16A/8.9A(AC220/230V, AC380/400V, AC660/690V);
AC-4:7.7A/7.7A/3.5A(AC220/230V, AC380/400V, AC660/690V);
TGCA-0911N: Ith:20A;
AC-1:20A(AC220/230V, AC380/400V);
AC-4:3.5A/3.5A/1.5A(AC220/230V, AC380/400V, AC660/690V);
TGCA-1211N: Ith:25A;
AC-1:25A(AC220/230V, AC380/400V);
AC-4:5A/5A/2A(AC220/230V, AC380/400V, AC660/690V);
TGCA-1611N: Ith:25A;
AC-1:25A(AC220/230V, AC380/400V);
AC-4:7.7A/7.7A/3.5A(AC220/230V, AC380/400V, AC660/690V);
Utilization category:
AC-1(TGCA-0911, TGCA-0911N, TGCA-1211, TGCA-1211N,
TGCA-1611, TGCA-1611N),



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE220302007538

AC-3(TGCA-0911,TGCA-1211,TGCA-1611),
AC-4(TGCA-0911,TGCA-0911N,TGCA-1211,TGCA-1211N,
TGCA-1611,TGCA-1611N);
Us:AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,
AC415V,50Hz;
AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;3P;
Auxiliary contact:1NO1NC;Uimp:6kV,Ui:690V,Ith:10A;
AC-15:Ue/Ie:AC380V/0.95A,AC220V/1.6A;
DC-13:AC220V/0.15A.



CHINA QUALITY CERTIFICATION CENTRE

