

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit breaker

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co.,Ltd.
No.332 Liule Road, LiuShi Town, Yueqing City, Zhejiang
Province

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGB1NLE-63Y,TGB1NLA-63Y;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 61009-1:2010(3rd Edition) + AMD 1:2012 + AMD
2:2013;IEC 61009-2-2:1991(1st Edition)As shown in the Test Report Ref. No. which
forms part of this Certificate

00901- CB2021CQC-100587

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.19,2022

Signature:


Xie ZhaoXu

TGB1NLE-63Y,TGB1NLA-63Y;

Uimp: 4kV;

Ui: 690V;

Ue: AC220/230/240V;

In: 6A,10A,16A,20A,25A,32A,40A,50A,63A;

Instantaneous tripping current: B,C,D;

$I\Delta n$: 0.015A,0.03A,0.05A,0.075A,0.1A,0.3A;

50Hz

Type AC, Type A/ Electronic Type;

$I\Delta m$:2000A;

Ics:6000A;

Icn:6000A;

Pole: 2P (2 protected poles), 1P+N(1 protected poles with an uninterrupted neutral pole);

Applicable for isolation(except for 1P+N)

Page 1 of 1

Additional information (if necessary)

Date: Jan.19,2022

Signature:

谢肇煦
Xie ZhaoXu