

CE TEST REPORT

Application No.:CE2021CQC0303-012512

Report Ref. No.: CE-045-1C213818

Name of product: Miniature Circuit-breaker

Model: TGBK-40A,TGB1N-40A,TGB1N-40N,TGBK-40N

Name of Laboratory: Zhejiang Testing & Inspection
Institute for Mechanical and
Electrical Products Quality Co.,Ltd.



CHINA QUALITY CERTIFICATION CENTRE

Test Report issued under the responsibility of:
Zhejiang Testing & Inspection Institute for Mechanical And
Electrical Products Quality Co.,Ltd.

TEST REPORT
IEC/EN 60898-1
**Circuit-breakers for over current protection for
household and similar installations**

Report Reference No. CE-045-1C213818

Date of issue 30.05.2022

Total number of pages 93 pages

Applicant's name Zhejiang Tengen Electrics Co.,Ltd.

Address Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Test specification:

Standard IEC 60898-1:2015+AMD1:2019 and/or

EN 60898-1:2019

Test procedure ~~CB~~ CCA

Non-standard test method N/A

Test Report Form No. IEC/EN60898_1E

Test Report Form(s) DEKRA Certification B.V.

Originator

Master TRF Dated 2020-04-17

Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

If this Test Report Form is used by non-CCA members, the CIG logo and the reference to the CCA Procedure shall be removed.

This report is not valid as a CCA Test Report unless signed by an approved CCA Testing Laboratory and appended to a CCA Test Certificate issued by an NCB in accordance with CCA

Test item description Miniature Circuit-breaker

Trade Mark 

Manufacturer Zhejiang Tengen Smart Electrics Co.,Ltd.

Model/Type reference TGBK-40A, TGB1N-40A, TGB1N-40N, TGBK-40N

Ratings TGBK-40A, TGB1N-40A, TGB1N-40N, TGBK-40N

Ue: AC220V/230V/240V; Ui: 500V; Uimp: 4kV; In: 6A, 10A, 16A, 20A, 25A, 32A, 40A;

Type: C, D; TGBK-40A, TGB1N-40A: Icn=Ics: 4500A; TGB1N-40N, TGBK-

40N: Icn=Ics: 6000A; 1P+N; 50/60Hz

| | | |
|---|--|---|
| Testing procedure and testing location: | | |
| | | |
| Responsible Testing Laboratory (as applicable), testing procedure and testing location(s): | | |
| <input checked="" type="checkbox"/> | Testing Laboratory: | Zhejiang Testing & Inspection Institute for Mechanical and Electrical Products Quality Co.,Ltd. |
| Testing location/ address | | No. 125 Miaohouwang Road Binjiang District Hangzhou, Zhejiang CHINA |
| Tested by (name, function, signature) | | Zhu Lin (Test engineer) <i>Zhu Lin</i> |
| Approved by (name, function, signature) .. | | Ma Lin (Approver) <i>Malin</i> |
| | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 1: | N/A |
| Testing location/ address | | N/A |
| Tested by (name, function, signature) | | N/A |
| Approved by (name, function, signature) .. | | N/A |
| | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 2: | |
| Testing location/ address | | N/A |
| Tested by (name + signature) | | N/A |
| Witnessed by (name, function, signature) . | | N/A |
| Approved by (name, function, signature) .. | | N/A |
| | | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 3: | N/A |
| <input type="checkbox"/> | Testing procedure: CTF Stage 4: | N/A |
| Testing location/ address | | N/A |
| Tested by (name, function, signature) | | N/A |
| Witnessed by (name, function, signature) . | | N/A |
| Approved by (name, function, signature) .. | | N/A |
| Supervised by (name, function, signature) : | | N/A |
| | | |

List of Attachments (including a total number of pages in each attachment):

Attachment 1: Photo documentation –90 pages

Summary of testing:

The type TGBK-40 is family circuit breaker of the same fundamental design. According to table C.3 of Annex A, following ratings products were subject relevant test accordingly.

Sample allocation and test items according to EN/IEC 60898-1

| Test sample Rating | | | Test sequence | | | | | | | | | |
|--------------------|-------|--------|---------------|----|---|----|----|-----------|----|----|----|----|
| Pole | Curve | In [A] | A1 | A2 | B | C1 | C2 | D0+ D1 | D0 | E1 | E2 | E3 |
| TGBK-40A/1P+N | D | 40 | 1 | 3 | 3 | 3 | 3 | 3 | - | 3 | - | 3 |
| TGBK-40A/1P+N | D | 32 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | D | 25 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | D | 20 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | D | 16 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | D | 10 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | D | 6 | - | - | - | - | - | - | 1 | 3 | - | - |
| TGBK-40A/1P+N | C | 40 | - | - | 3 | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | C | 32 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | C | 25 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | C | 20 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | C | 16 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | C | 10 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40A/1P+N | C | 6 | - | - | - | - | - | - | 1 | - | - | - |
| TGBK-40N/1P+N | D | 40 | 1 | - | - | - | - | - | - | 3 | - | - |
| TGBK-40N/1P+N | D | 6 | - | - | - | - | - | - | - | 3 | - | - |