



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007723

Product

Miniature Circuit Breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGBK-40A,TGB1N-40A,TGB1N-40N,TGBK-40N;

Technical data

Ue:AC220V/230V/240V;Ui:500V;Uimp:4kV;In:6A,10A,16
A,20A,25A,32A,40A;

Type:C,D;TGBK-40A,TGB1N-40A: Icn=Ics:4500A;TGB1N
-40N,TGBK-40N:Icn=Ics:6000A; 1P+N(with one
protected pole,switched N pole);50/60Hz

This is to certify that, on the basis of the tests undertaken as per Report No.
CE-045-1C213818, the submitted sample(s) of the above item complies with:

EN 60898-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jul.20,2022

Valid until: Jul.19,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

