



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220302007718

Product

AC contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGCA-4011,TGCA-4011N,TGCA-5011,TGCA-5011N,TGC
A-6511,TGCA-6511N

Technical data

See the attachment

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-21D0088-S-A;03601-A-21D0088-S-B, the submitted sample(s) of the above
item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jun.21,2022

Valid until: Jun.20,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE220302007718

TGCA-4011, TGCA-4011N, TGCA-5011, TGCA-5011N, TGCA-6511, TGCA-6511N

Ui: 690V; Uimp: 6kV;

Ith: TGCA-4011, TGCA-4011N: 60A;

TGCA-5011, TGCA-6511, TGCA-5011N, TGCA-6511N: 80A;

AC-1: TGCA-4011, TGCA-4011N: Ue/Ie: 220V/230V; 380V/400V/60A;

TGCA-5011, TGCA-6511, TGCA-5011N, TGCA-6511N:

Ue/Ie: 220V/230V; 380V/400V/80A;

AC-3: TGCA-4011: Ue/Ie: 220V/230V/40A; 380V/400V/40A; 660V/690V/34A;

TGCA-5011: Ue/Ie: 220V/230V/50A; 380V/400V/50A; 660V/690V/39A;

TGCA-6511: Ue/Ie: 220V/230V/65A; 380V/400V/65A; 660V/690V/42A;

AC-4:

TGCA-4011, TGCA-4011N:

Ue/Ie: 220V/230V/18.5A; 380V/400V/18.5A; 660V/690V/9A;

TGCA-5011, TGCA-5011N: Ue/Ie: 220V/230V/24A; 380V/400V/24A; 660V/690V/12A;

TGCA-6511, TGCA-6511N: Ue/Ie: 220V/230V/28A; 380V/400V/28A; 660V/690V/14A;

Us: AC24V, AC36V, AC48V, AC110V, AC220V, AC380V, AC400V, AC415V, 50Hz;

AC24V, AC36V, AC48V, AC110V, AC220V, AC380V, AC400V, AC415V, 50/60Hz;

Utilization category: AC-1, AC-3, AC-4;

Number of poles: 3P;

IP20;

Attached auxiliary contact: 1NO, 1NC, 2sets; Ith: 10A; Ui: 690V; Uimp: 6kV;

AC-15: 1.6A/220V, 0.95A/380V, DC-13: 0.15A/220V.



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE220302007718

Explanation of model/type

TG C A - □ □ □

Normal: /; N: Reversible Contactor

Attached auxiliary contacts: 11: 1NO1NC

Rated current(A) under AC-3 utilization category and
rated operational voltage 380V/400V

Design serial number

AC Contactor

Enterprise code



CHINA QUALITY CERTIFICATION CENTRE

