



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007923

**Product**

Moulded Case Circuit Breaker

**Applicant**

Zhejiang Tengen Smart Electrics Co.,Ltd.

No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,  
Zhejiang Province, P.R.China

**Type/Model**

TeM5DC-400HU;

**Technical data**

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 02401-22119Y29053, the submitted sample(s) of the above item complies with:

**EN 60947-2:2017/A1:2020;EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from:** Dec.01,2022

**Valid until:** Nov.30,2025

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

**Appendix**

**Page 1 of 1**

**Certificate No.: CE220303007923**

TeM5DC-400HU;  
Ui:1500V;Uimp:12kV;  
Ue:DC1500V;  
In:225A,250A,315A,350A,400A;  
Type of overcurrent release: Thermo-magnetic trip unit, Electro-magnetic trip unit;  
Selectivity category:A;  
Ics:20kA(M type/T=10ms),40kA(H type/T=5ms);  
Icu:20kA(M type/T=10ms),40kA(H type/T=5ms);  
Wiring mode:4P appearance;  
The product is suitable for isolation;  
Applicable to PV  
(Only the nameplate reflects "IEC 60947-2- Annex P");  
Electronic accessories complying with Annex N:  
Undervoltage:  
Us:AC220/230V;  
Electric operation:Us: AC220/230V;  
Auxiliary:1NO1NC,2NO2NC,4NO4NC:Ith:6A;  
AC-15:AC380/400V/1.5A;  
DC-13:DC220/250V/0.15A.



**CHINA QUALITY CERTIFICATION CENTRE**

