




TEST REPORT EN 60947-2 Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	
Report Number:	02401-22119Y29054-1
Date of issue:	2022-11-05
Total number of pages	80
Name of Testing Laboratory preparing the Report:	Zhejiang Fangyuan Test Group CO., Ltd. No.400,Guangqiong Rd, Jiaxing City, Zhejiang Province. P.R. China
Applicant's name	Zhejiang Tengen Smart Electrics Co.,Ltd.
Address:	No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
Test specification:	
Standard:	EN 60947-2:2017+A1:2020
Test procedure	CCA Scheme
Non-standard test method	N/A
Test Report Form No.	IEC 60947_2J
Test Report Form(s) Originator	DEKRA Certification B.V.
Master TRF:	Dated 2020-03-31
<p>Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</p> <p>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</p> <p>If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.</p> <p>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</p>	
General disclaimer:	
<p>The test results presented in this report relate only to the object tested.</p> <p>This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>	
Test item description	Moulded Case Circuit Breaker
Trade Mark(s):	
Manufacturer	Zhejiang Tengen Smart Electrics Co.,Ltd. No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China

Model/Type reference	TeM5DC-250HU;	
Ratings	Ui:1500V;Uimp:12kV;	
	Ue:DC1500V;	
	In:63A,80A,100A,125A,140A,160A,180A,200A,225A,250A;	
	Type of overcurrent release:	
	Thermo-magnetic trip unit, Electro-magnetic trip unit;	
	Selectivity category:A;	
	M type:Ics=Icu:20kA(τ=10ms);	
	H type:Ics=Icu:40kA(τ=5ms);	
	Wiring mode:3P appearance;	
	The product is suitable for isolation;	
	Applicable to PV	
	(Only the nameplate reflects "IEC 60947-2- Annex P");	
	Auxiliary:1NO1NC,2NO2NC;lth:3A;	
	AC-15:Ue/ Ie:AC400V/1.5A;	
	DC-13:Ue/ Ie:DC220V/0.15A;	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CE Testing Laboratory:	Zhejiang Fangyuan Test Group CO., Ltd
	Testing location/ address	No.400,Guangqiong Rd, Jiaxing City, Zhejiang Province. P.R. China
	Tested by (name, function, signature)	Jin Hongfei 
	Approved by (name, function, signature) ...:	Yao Bo 
<input type="checkbox"/>	Testing procedure: CTF Stage 1:	
	Testing location/ address	
	Tested by (name, function, signature):	
	Approved by (name, function, signature) ...:	
<input type="checkbox"/>	Testing procedure: CTF Stage 2:	
	Testing location/ address	
	Tested by (name + signature)	
	Witnessed by (name, function, signature)..:	
	Approved by (name, function, signature) ...:	
<input type="checkbox"/>	Testing procedure: CTF Stage 3:	
<input type="checkbox"/>	Testing procedure: CTF Stage 4:	
	Testing location/ address	
	Tested by (name, function, signature):	
	Witnessed by (name, function, signature)..:	
	Approved by (name, function, signature) ...:	
	Supervised by (name, function, signature) :	

List of Attachments (including a total number of pages in each attachment): N/A

Summary of testing:

Standard used :

EN 60947-2:2017+A1:2020; EN 60947-1:2007+A2:2014;

In case of alternative test programs for circuit breakers with a different number of poles, the following program is used:

Programme 1 (three pole fully tested)

Programme 2 (four pole fully tested)

Alternative program not applicable

Tests performed (name of test and test clause):

Sample No.	Type	Poles	Rated Current	Test Voltage	Short circuit current	Test sequence
I-1#	TeM5DC-250HUM/3348	3P	250A	DC1500V	-	I
II-1#	TeM5DC-250HUM/3300	3P	250A	DC1500V	20kA	II+III
II-2#	TeM5DC-250HUM/3300	3P	63A	DC1500V	20kA	II+III
II-3#	TeM5DC-250HUM/3300	3P	250A	DC1500V	40kA	II+III
II-4#	TeM5DC-250HUM/3300	3P	63A	DC1500V	40kA	II+III
II-5#	TeM5DC-250HUM/3300	3P	250A	DC1500V	20kA	II+III
II-6#	TeM5DC-250HUM/3300	3P	250A	DC1500V	40kA	II+III
P-1#	TeM5DC-250HUM/3300	3P	250A	DC1500V	-	P.8.3.9
P-2#	TeM5DC-250HUM/3300	3P	250A	DC1500V	-	P.8.3.10
P-3#	TeM5DC-250HUM/3300	3P	250A	DC1500V	-	P.8.3.11

Note1:II-5#~II-6# with Reverse wiring

Note2:auxiliary circuit:Report No. 020401-22119Y29054-2

Connection diagram:

