



<b>TEST REPORT</b> <b>EN 60947-2</b> <b>Low-voltage switchgear and controlgear - Part 2: Circuit-breakers</b>	
<b>Report Number</b> .....:	02402-23119Y29023
<b>Date of issue</b> .....:	2023-05-08
Total number of pages .....	163
<b>Name of Testing Laboratory preparing the Report</b> .....:	Zhejiang Fangyuan Test Group CO., Ltd. National Center Of Quality Inspection For Electrical Safety (ZheJiang) No.400,Guangqiong Rd, Jiaxing City, Zhejiang Province. P.R. China
<b>Applicant's name</b> .....	Zhejiang Tengen Smart Electrics Co.,Ltd.
<b>Address</b> .....:	No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
<b>Test specification:</b>	
<b>Standard</b> .....:	EN 60947-2:2017+A1:2020
<b>Test procedure</b> .....	CCA Scheme
<b>Non-standard test method</b> .....	N/A
<b>Test Report Form No.</b> .....	IEC60947_2J
<b>Test Report Form(s) Originator</b> ....:	DEKRA Certification B.V.
<b>Master TRF</b> .....:	Dated 2020-03-31
<b>Copyright © 2020 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b> This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. <b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
<b>General disclaimer:</b>	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	
<b>Test item description</b> .....	Air circuit breaker
<b>Trade Mark(s)</b> .....:	/
<b>Manufacturer</b> .....	Zhejiang Tengen Smart Electrics Co.,Ltd. No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing, Zhejiang Province, P.R.China
<b>Model/Type reference</b> .....	TeW5-2500,TeW5-2500/4,TeW5F-2500,TeW5F-2500/4,
<b>Ratings</b> .....	TeW5F-2500HU,TeW5F-2500HU/4; Ui:1250V;Uimp:12kV; In:630A,800A,1000A,1250A,1600A,1900A,2000A,2500A; TeW5-2500,TeW5-2500/4,TeW5F-2500,TeW5F-2500/4:

