



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230305008136

Product

AC contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGC1-2511,TGC1-2511N,TGC1-3211,TGC1-3211N,TGC1-3811,TG
C1-3811N,TGCG-2511,
TGCG-2511N,TGCG-3211,TGCG-3211N,TGCG-3811,TGCG-3811
N,TGCJH-2511,TGCJH-2511N,
TGCJH-3211,TGCJH-3211N,TGCJH-3811,TGCJH-3811N,TGCK-2
511,TGCK-2511N,TGCK-3211,
TGCK-3211N,TGCK-3811,TGCK-3811N,TGC1-2511x,TGC1-2511x
N,TGC1-3211x,TGC1-3211xN, TGC1-3811x,TGC1-3811xN

Technical data

See the attachment

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-22D0157-S-A;03601-A-22D0157-S-B, the submitted sample(s) of the above
item complies with:

EN IEC 60947-4-1:2019;EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Apr.18,2023

Valid until: Apr.17,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.:CE230305008136

TGC1-2511,TGC1-2511N,TGC1-3211,TGC1-3211N,TGC1-3811,TGC1-3811N,TGCG-2511,
TGCG-2511N,TGCG-3211,TGCG-3211N,TGCG-3811,TGCG-3811N,TGCJH-2511,TGCJH-2511N,
TGCJH-3211,TGCJH-3211N,TGCJH-3811,TGCJH-3811N,TGCK-2511,TGCK-2511N,TGCK-3211,
TGCK-3211N,TGCK-3811,TGCK-3811N,TGC1-2511x,TGC1-2511xN,TGC1-3211x,TGC1-3211xN,
TGC1-3811x,TGC1-3811xN;

Ui:690V;Uimp:6kV;

Ith:40A(TGC1-2511,TGC1-2511x,TGC1-2511xN,TGC1-2511N,TGCG-2511,TGCG-2511N,
TGCJH-2511,TGCJH-2511N,TGCK-2511,TGCK-2511N),

50A(TGC1-3211,TGC1-3211x,TGC1-3211xN,TGC1-3211N,TGCG-3211,TGCG-3211N,TGCJH-3211,
TGCJH-3211N,TGCK-3211,TGCK-3211N),

50A(TGC1-3811,TGC1-3811x,TGC1-3811xN,TGC1-3811N,TGCG-3811,TGCG-3811N,TGCJH-3811,
TGCJH-3811N,TGCK-3811,TGCK-3811N);

TGC1-2511,TGC1-2511x ,TGCG-2511,TGCJH-2511,TGCK-2511:

AC-1:Ue:AC220V/230V,380V/400V Ie:40A

AC-3:Ue:AC220V/230V,380V/400V Ie:25A

Ue:AC660V/690V Ie:18A

AC-4:Ue:AC220V/230V,380V/400V Ie:8.5A

Ue:AC660V/690V Ie:4.4A

TGC1-2511N,TGC1-2511xN,TGCG-2511N,TGCJH-2511N,TGCK-2511N:

AC-1:Ue:AC220V/230V,380V/400V Ie:40A

AC-4:Ue:AC220V/230V,380V/400V Ie:8.5A

Ue:AC660V/690V Ie:4.4A

TGC1-3211,TGC1-3211x,TGCG-3211,TGCJH-3211,TGCK-3211:

AC-1:Ue:AC220V/230V,380V/400V Ie:50A

AC-3:Ue:AC220V/230V,380V/400V Ie:32A

Ue:AC660V/690V Ie:22A

AC-4:Ue:AC220V/230V,380V/400V Ie:12A

Ue:AC660V/690V Ie:7.5A

TGC1-3211N,TGC1-3211xN,TGCG-3211N,TGCJH-3211N,TGCK-3211N:

AC-1:Ue:AC220V/230V,380V/400V Ie:50A

AC-4:Ue:AC220V/230V,380V/400V Ie:12A

Ue:AC660V/690V Ie:7.5A



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.:CE230305008136

TGC1-3811,TGC1-3811x,TGCG-3811,TGCJH-3811,TGCK-3811:

AC-1:Ue:AC220V/230V,380V/400V Ie:50A

AC-3:Ue:AC220V/230V,380V/400V Ie:38A

Ue:AC660V/690V Ie:22A

AC-4:Ue:AC220V/230V,380V/400V Ie:14A

Ue:AC660V/690V Ie:8.9A

TGC1-3811N,TGC1-3811xN,TGCG-3811N,TGCJH-3811N,TGCK-3811N:

AC-1:Ue:AC220V/230V,380V/400V Ie:50A

AC-4:Ue:AC220V/230V,380V/400V Ie:14A

Ue:AC660V/690V Ie:8.9A

Utilization category:AC-1,AC-3,AC-4;

Us:AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50Hz;

AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;

3P;IP20;

Attached auxiliary contacts (1NO,1NC,2 sets):

Ith:10A;Ui:690V;Uimp:6kV;

AC-15:Ue/Ie:AC380V/0.95A, AC220V/1.6A

DC-13:Ue/Ie:DC220V/0.15A.

Explanation of model/type

TG C □ - □□ 11 □ □

(1) (2) (3) (4) (5) (6) (7)

(1) Enterprise code

(2) AC Contactor

(3) Design serial number (1,G,JH and K are named according to different sales channels)

(4) AC-3 Uses 380V/400V limit working current

(5) Type and logarithm of auxiliary contacts: 11: 1NO+1NC

(6) Routine: omit not to write as derived money;x: Regular

(7) Routine: omit not write; N: reversible AC contactor



CHINA QUALITY CERTIFICATION CENTRE

