



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-241823-EA

Certificate Holder: Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Regulatory Definition: Miniature Overcurrent Circuit-Breaker

Product Description: Circuit Breaker for Overcurrent Protection
(Miniature Circuit Breaker)

Standard/s: AS/NZS 60898.1:2024

Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-241823-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 9 January 2025

Expiry Date: 9 January 2030

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 09-01-25 241823
Page 1 of 2



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating/Marking
TGB1N-63A	TENGEN	Ue: AC 220V/380V, 230V/400V, 240V/415V (1P); AC 220V/230V/240V (1P+N, 2P); AC 380V/400V/415V (2P, 3P, 3P+N, 4P); In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Ics=Icn: 4500A Type B, C, D
TGBG-63A	TENGEN	Ue: AC 220V/380V, 230V/400V, 240V/415V (1P); AC 220V/230V/240V (1P+N, 2P); AC 380V/400V/415V (2P, 3P, 3P+N, 4P); In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Ics=Icn: 4500A Type B, C, D
TGB1N-63	TENGEN	Ue: AC 220V/380V, 230V/400V, 240V/415V (1P); AC 220V/230V/240V (1P+N, 2P); AC 380V/400V/415V (2P, 3P, 3P+N, 4P); In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Ics=Icn: 6000A Type B, C, D
TGBG-63	TENGEN	Ue: AC 220V/380V, 230V/400V, 240V/415V (1P); AC 220V/230V/240V (1P+N, 2P); AC 380V/400V/415V (2P, 3P, 3P+N, 4P); In: 1A, 2A, 3A, 4A, 5A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Ics=Icn: 6000A Type B, C, D

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 09-01-25 241823
Page 2 of 2