



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240305009327

Product

DC contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGCZP-150,TGCZC-150,TGCZQ-150,
TGCZP-200,TGCZC-200,TGCZQ-200,
TGCZP-250,TGCZC-250,TGCZQ-250,
TGCZP-300,TGCZC-300,TGCZQ-300

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
C-14201-DC2412737, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Dec.30,2024

Valid until: Dec.29,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE240305009327

TGCZP-150,TGCZC-150,TGCZQ-150

Usage category: DC-1 Ui:1500V;Uimp:6kV;

Ue:DC1500V,DC1000V,DC750V;Ith:300A

Ie(A):1500VDC×50A:1000VDC×100A: 750VDC×150A;

Us:12VDC,24VDC,9~36VDC

Auxiliary circuit:Use category DC-12 Ue:30VDC; Ie:0.5A; Ith:0.5A;Uimp:1.5kV;

Contact form: 1NO;

TGCZP-200,TGCZC-200,TGCZQ-200

Usage category: DC-1 Ui: 1500V;Uimp:6kV;

Ue:DC1500V,DC1000V,DC750V;Ith:300A

Ie(A): 1500VDC×50A: 1000VDC×100A: 750VDC×200A;

Us:12VDC,24VDC,9~36VDC

Auxiliary circuit: Use category DC-12 Ue:30V DC; Ie:0.5A; Ith:0.5A;Uimp:1.5kV;

Contact form: 1NO;

TGCZP-250,TGCZC-250,TGCZQ-250

Usage category: DC-1 Ui: 1500V;Uimp:6kV;

Ue:DC1500V,DC1000V,DC750V;Ith:300A

Ie(A): 1500VDC×50A: 1000VDC×100A: 750VDC×250A;

Us:12VDC,24VDC,9~36VDC

Auxiliary circuit: Use category DC-12 Ue:30V DC; Ie:0.5A; Ith:0.5A;Uimp:1.5kV;

Contact form: 1NO;

TGCZP-300,TGCZC-300,TGCZQ-300 ; Usage category: DC-1 Ui: 1500V;Uimp:6kV;

Ue:DC1500V,DC1000V,DC750V;Ith:300A

Ie(A): 1500VDC×50A: 1000VDC×100A: 750VDC×300A;

Us:12VDC,24VDC,9~36VDC

Auxiliary circuit: Use category DC-12 Ue:30V DC; Ie:0.5A; Ith:0.5A;Uimp:1.5kV;Contact form: 1NO



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE